

II. New or Expanded Facility Permits, Renewal of Major Permits and EPA Nonwaived Permit Actions

Southwest Regional Office: Regional Clean Water Program Manager, 400 Waterfront Drive, Pittsburgh, PA 15222-4745. Phone: 412.442.4000.

NPDES Permit No. PA0254771, SIC Code 4911, Tenaska PA Partners LLC, 1044 N 115 Street, Omaha, NE 68154.

This proposed facility is located in South Huntingdon Township, Westmoreland County.

Description of Proposed Action/Activity: Issuance of an NPDES Permit for a new discharge of treated cooling tower blowdown, low volume wastes, stormwater associated with industrial activity and uncontaminated stormwater from a steam electric generating facility.

Changes from draft permit: Monitoring requirements were imposed for lead and chromium (VI) at outfall 001. The following Part C condition was also established:

Not before 90 days or later than 180 days of commencement of the Outfall 001 discharge Tenaska shall sample and analyze one influent sample and three effluent samples at Outfall 001 for those pollutants listed in pollutant groups 1-5 of the NPDES Application for Individual Permit to Discharge Industrial Wastewater. The sample results shall be submitted within 240 days upon commencement of the Outfall 001 discharge. The data shall be submitted on the application tables found on pages 11-18 of the application. The data shall be submitted to:

PADEP- SWRO
Clean Water- ATTN IW Permits Chief
400 Waterfront Dr.
Pgh, PA 15222

PADEP- New Stanton Regional Office
Clean Water- Water Quality Specialist South Huntingdon Twp
131 Broadview Road
New Stanton, PA 15672

There are no changes to any previously noticed effluent limitations.